

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 272Dated: 16/4/25

It is certified that an inspection team headed by Mr. Devendra Singh Gound
(Name of Officers with designation) from Mr. Devendra Singh Gound Assistant Engineer
PHED inspected the **HOLY ANGELS KIDS ACADEMY, NH-46, NEAR BUS STAND, KURAWAR, DIST RAJGARH, MP** on
15-04-2025 and on the basis of Water Test Report (Attached) bearing no. 109 dated 15-04-2025
of Public Health Engineering Department Narsinghgarh (PHED Lab) certified
that the **HOLY ANGELS KIDS ACADEMY, NH-46, NEAR BUS STAND, KURAWAR, DIST RAJGARH, MP** has safe drinking
water facilities for the students and members of staff of the institution. School is also maintains the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T.
Govt.

This certificate is valid till 1 year

Signature with seal

Name

Designation

Name & address of the office/Department :- P.H.E. Narsinghgarh Samajpol

To,
HOLY ANGELS KIDS ACADEMY,
NH-46, NEAR BUS STAND, KURAWAR, DIST RAJGARH, MP
(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies


Principal
Holy Angels Kids Academy
Kurawar Mandi, Rajgarh (Dt.) M.P.


Secretary
Fourj kids welfare society samiti
Kurawar Mandi (Dt.) Rajgarh M.P.

SUB DIVISION WATER TESTING LABORATORY
Public Health Engineering Sub Division Narsingharh Dist. Rajgarh


ANALYSIS REPORT

Kind of Sample	: Drinking Water			
PATICULARS OF SENDER	: HOLY ANGELS KIDS ACADEMY KURAWAR			
Ref No. and Date	: 15-04-2025			
PARTICULARS OF SAMPLE	: 01			
Sample No.	Place Of Collection and Details of Sample			
	City	Blocks	Source	Location
1	Kurawar	Narsingharh	T.W.	Holy Angels Kids Academy NH 46 Near Bus Stand
PARTICULARS TO BE FILLED IN THE LABORATORY				
Date of Receipt:- 15-04-2025			Date of Testing:- 16-04-2025	

NATURE OF STUDY – PHYSICAL CHEMICAL & BACTERIOLOGICAL ANALYSIS


S.No.	Characteristics	Unit	As per BIS – 10500:2012 for Drinking Water		Results				
			Requirement (Desirable Limit)	Permissible limit in the absence of Alternative source	Sample	Sample	Sample	Sample	Sample
					1	2	3	4	5
PHYSICAL TESTS									
1	Temperature	°c	-----	-----		-	-	-	-
2	Turbidity	NTU	1.0	5-0	0.5	-	-	-	-
3	Colour	Hazen Units	5	15	Nil	-	-	-	-
4	Taste Odour	-----	Unobjectionable	Objectionable	Nil	-	-	-	-
CHEMICAL TESTS									
5	pH	pH Scale	6.5 to 8.5	No Relaxation	7.40	-	-	-	-
6	Conductivity at 25°C	Micromhos Per cm°	-	-	890.6	-	-	-	-
7	Alkalinity	Mg/l	200	600	280	-	-	-	-
8	Chlorides as Cl	Mg/l	250	1000	250	-	-	-	-
9	Nitrate as NO3	Mg/l	45	45	0	-	-	-	-
10	Total Hardness	Mg/l	200	600	230	-	-	-	-
11	Calcium as Ca	Mg/l	75	200	44	-	-	-	-
12	Magnesium as Mg	Mg/l	30	100	21.6	-	-	-	-
13	Total Dissolved Solids	Mg/l	500	2000	1260	-	-	-	-
14	Iron	Mg/l	0.3	0.3	0	-	-	-	-
15	Fluoride as F	Mg/l	1.0	1.5	0.5	-	-	-	-
16	Residual Chlorine as Cl	Mg/l	0.2	1.0	0	-	-	-	-
17	Sulphate as SO4	Mg/l	200	400	78.6	-	-	-	-
COAGULANT DOSE									
BACTERIOLOGICAL TESTS									
18	M.PN of Coli form	-	Nil		-	-	-	-	-
19	Fecal Coli form	-	Nil		0/100ml	-	-	-	-

NOTE:- The figures indicated under the column "Requirement (Desirable Limit)" the limits upto which water is generally acceptable to the consumers. Figures in excess of those mentioned under "Requirement (Desirable Limit)" the water not acceptable, but . Still may be tolerated in the absence of an alternative and better source but upto the limits indicated under column "Permissible Limit in the absence of Alternative Source" above which the source will have to be rejected.
 (Guideline values for drinking water as per BIS 10500)


Chemist
 Sub Divisional Water Testing Laboratory
 P.H.E.D. Sub division Narsingharh


Assistant Engineer
 PHE Sub Division Narsingharh
 District Rajgarh


Principal
 Holy Angels Kids Academy
 Kurawar Mandi, Rajgarh (Dt.) M.P.


Secretary
 Fourj kids welfare society samiti
 Kurawar Mandi (Dt.) Rajgarh M.P.